



HPI Verification Services

# Type Examination Certificate

This is to certify that the product listed below conforms to the requirements of the

## Pressure Equipment Directive

97/23/EC Annex III Module B

<b>Certificate Number</b>	HPIVS/P1002-112-I-01 rev. 1	<b>Date of Expiry</b>	01-Jun-2025
<b>Date of Issue</b>	22-Nov-2018		
<b>Designer</b>	<b>Xi'an Westpeace Fire Technology Co., Ltd.</b> ROOM 705, BUILDING 6, NO. 65, KEJI 2ND ROAD, GAOXIN DISTRICT, XI'AN CITY, SHAANXI PROVINCE, CHINA		
<b>Description of Pressure Equipment</b>	Portable Nano Particles Disposable Fire Extinguisher Type: JE-50&PFE-1, JE-100&PFE-3, JE-150&PFE-2, JE-300&PFE-4. Cylinder material: Q/BQB 403-2009 DC06		
<b>Drawing No</b>	JE-50-C-00; JE-100-C-00; JE-150-C-00, JE-300-C-00;		
<b>Serial No</b>	Not applicable		
<b>Design Pressure</b>	PS: 12 bar (min burst tests 120 bar)		
<b>Design Temperature</b>	-20 to 60 °C		
<b>Standards Used</b>	BS 6165, EN 3-7, EN 3-8, EN 3-10, Q/JR 007-2013		
<b>Report Reference</b>	P1002-112-1 and P1002-112-DR01		

This Certificate is valid in any European Economic Area Member State.

This Certificate has been issued by HPI Verification Services Ltd which is a body notified to the European Commission according to the provisions of the Pressure Equipment Directive (Notified Body number 1521).

This Certificate is issued following the assessment of a representative sample of the Pressure Equipment detailed above in accordance with the provisions of the above regulations. The equipment must be subject to an appropriate conformity assessment module during manufacture prior to the CE Mark being affixed.

Check this certificate is genuine



Managing Director

Technical Director



EU Notified Body No. 1521  
Company registered in England #7217086

© HPI Verification Services Ltd. 2018

Tel +44 1491 822818  
Fax +44 700 600 6831  
Email [enquiries@eucertification.com](mailto:enquiries@eucertification.com)  
[www.eucertification.com](http://www.eucertification.com)

HPI Verification Services Ltd.  
The Manor House  
Howbery Park, Wallingford  
OX10 8BA, United Kingdom